

Attachment 3

TESTING SCHEDULE FOR MONTHS
OTHER THAN JANUARY AND JULY

1. South Half of Headquarters Building:

Total outage of commercial power from 1900 to 2200 hours but with no discernible effect on critical power and frantic power. Normal service is resumed at 2200 hours.

2. North Half of Headquarters Building:

Total outage of commercial power and emergency power at 1900 hours but with no discernible effect on critical power and frantic power. Emergency power returns at approximately 1915 hours. Normal service is resumed at 2200 hours.